# The Regional Municipality of Durham

# **Greenbank Drinking Water System 2024 Annual Report**

**Drinking Water System Number**: 220003760

Municipal Drinking Water Licence Number: 003-104

**Drinking Water System Owner**: The Regional Municipality of Durham

**Drinking Water System Category**: Large Municipal Residential

This Annual Report for the calendar year 2024 is designed to inform you about your drinking water system. This report has been prepared to satisfy Section 11 of Ontario Regulation (O. Reg.) 170/03. O. Reg. 170/03 sets requirements for drinking water systems with regard to sampling and testing, levels of treatment, certification of staff, and notification of authorities and the public about water quality. Hard copies of this report and the Schedule 22 Summary Report are available at the Regional Municipality of Durham Headquarters office that is located at 605 Rossland Road East, Whitby. The annual report is also available on the Region of Durham's website at www.durham.ca. Further information regarding the Drinking Water Regulations can be found on the Ministry of the Environment Conservation and Parks website at www.ontario.ca/ministry-environment-conservation-parks.

### **Drinking Water System Process Description**

#### General

The Greenbank Drinking Water System provides potable water to consumers in the Community of Greenbank in the Township of Scugog. Greenbank has five municipal wells designated as Well No. 1, Well No. 3, Well No. 4, Well No. 5 and Well No. 6. Greenbank is a Class One Distribution and Supply Subsystem with an approved combined capacity of 553 cubic metres per day (m³/d). The Greenbank Well Supply System feeds a Class One Distribution Subsystem. The Greenbank supply and distribution systems are owned and operated by the Regional Municipality of Durham. The water supply system includes the following processes:

- Raw Water Supply,
- Disinfection (sodium hypochlorite),
- · Water storage and high lift pumping, and
- Distribution.

### **Raw Water Supply**

Water is pumped from five municipal wells within Greenbank to the reservoir for treatment. Wells No.1, 3, 4, 5 and 6 are drilled to a depth of 28.8 metres (m), 24.1 m, 34.1 m, 32.2 m and 29.1 m, respectively.

#### Disinfection

The raw water is disinfected with sodium hypochlorite as it enters the reservoir. The free chlorine residual and turbidity are monitored continuously by online analyzers on the treated water.

# Water Storage and High Lift Pumping

Treated water is stored in a 671 cubic metre three-cell below ground storage reservoir. From here the treated water flows to the high lift suction well. Pressure in the system is maintained by high lift pumps and five hydropneumatic tanks.

### **Distribution System**

The distribution system delivers the treated water through approximately 7 kilometres of watermains. There is no water storage in the distribution system.

### Major Monetary Expenses (above \$50,000)

Under Section 11 of O. Reg. 170/03, a description of any major expenses incurred during this reporting period to install, repair or replace required equipment must be included in the annual report. The details of major expenses for this drinking water system are as follows:

There were no major expenses incurred during this reporting period

#### **Tables**

For a description of terms and abbreviations in all tables, refer to the glossary at the end of the report.

## **Greenbank Drinking Water System (DWS) Table 1**

Summary of all Adverse Water Quality Incidents in 2024 Reported to Spills Action Centre in Accordance with Schedule 16-3 and 16-4 of O. Reg. 170/03.

No adverse water quality incidents occurred in 2024.

#### **Greenbank DWS Table 2**

Microbiological Membrane Filtration (MF) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Range of Escherichia	Range of Total Coliforms MF
		coli MF Colony	Colony Forming Units per 100
		Forming Units per	Millilitres
		100 Millilitres	
Raw	250	Non-Detect (ND)	ND - 11
Treated	2	ND	ND
Distribution	1	ND	ND

### **Greenbank Table 3**

Microbiological Presence Absence (P/A) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Escherichia coli P/A per 100 Millilitres	Total Coliforms P/A per 100 Millilitres
Treated	53	Absence (A)	Α
Distribution	155	A	Α

#### **Greenbank DWS Table 4**

Microbiological Heterotrophic Plate Count (HPC) Testing Under Schedule 10 of O. Reg. 170/03.

Type of Sample	Number of Samples	Range of HPC Samples Colony
		Forming Units per Millilitre
Treated	55	Non-Detect (ND) – 8
Distribution	79	ND - 579

# Operational Testing Under Schedule 7 of O. Reg. 170/03.

Test	Number of Samples	Range of Results	Unit of Measure	Parameter Description
Turbidity - Raw Water	245	0.04 - 0.52	Nephelometric Turbidity Units (NTU)	Turbidity is a measure of particles in water.
Free Chlorine - Plant	Continuous	0.66 – 1.76*	Milligram per Litre (mg/L)	Must be sufficient to ensure disinfection has been achieved.
Free Chlorine - Distribution	Continuous	0.60 - 1.56*	mg/L	Recommended level of at least 0.20 mg/L in the distribution system to maintain secondary disinfection, 0.05 mg/L is the minimum required.

<sup>\*</sup>Results include all analyzers and grab samples.

Summary of Treated Water Chemical Parameter Testing Under Schedules 13 and 23 of O. Reg. 170/03.

Parameter	Number of	Results Range	MAC	Unit of	MAC	Potential Sources*
	Samples			Measure	Exceedance	
Antimony	5	Non-Detect (ND)	0.006	Milligram per	No	Fire retardants, ceramics,
				Litre (mg/L)		electronics, solder.
Arsenic	5	ND - 0.0006	0.01	mg/L	No	Mining.
Barium	1	0.082	1.0	mg/L	No	Metal refineries, oil drilling.
Boron	1	0.023	5.0	mg/L	No	Industrial.
Cadmium	5	ND	0.005	mg/L	No	Industrial.
Chromium	5	ND	0.05	mg/L	No	Industrial.
Total Haloacetic	4	2.8	80	Microgram per	No	By-product of chlorination of
acids - Distribution				Litre (ug/L)		drinking water.
(annual average)						
Mercury	2	<0.05 - <0.1	0.001	mg/L	No	Industrial.
Selenium	5	ND	0.05	mg/L	No	Refineries, mines, chemical
						manufacturing.
Sodium	4	17.5 – 36.7	Not	mg/L	Yes (2)***	Storm water runoff including road
			Applicable**			salt.
Total	4	15.4	100	ug/L	No	By-product of chlorination of
Trihalomethanes -						drinking water.
Distribution (annual						
average)						
Uranium	1	0.0016	0.02	mg/L	No	Power generation.
Fluoride	4	0.07 – 0.1	1.5	mg/L	No	Mining.
Nitrite	4	ND	1.0	mg/L	No	Agriculture runoff, landfill leachate
						and animal waste.
Nitrate	4	0.95-1.15	10.0	mg/L	No	Fertilizer.

<sup>\*</sup> Parameters may occur naturally in the environment.

<sup>\*\*</sup> Sodium does not have a Maximum Acceptable Concentration (MAC); only an aesthetic objective of 200 mg/L. Sodium results exceeding 20 mg/L are to be reported to the Medical Officer of Health as per Schedule 16-3 (8) of O. Reg. 170/03.

<sup>\*\*\*</sup> Number in parenthesis represents number of exceedance(s). For Sodium, regulations require reporting when results exceed 20 mg/L if it has not been reported in the preceding 57 months.

# Summary of Lead Testing Under Schedule 15.1 of O. Reg. 170/03.

No plumbing samples were required to be taken in 2024.

Location Type	Number of Samples	Range of Lead Results Milligram per Litre	MAC	Number of Exceedances	рН	Alkalinity Milligram per Litre
Plumbing	Not Required (N/R)	N/R	0.01	N/R	N/R	N/R
Distribution	4	Non-Detect – 0.0034	0.01	0	7.5 - 7.6	220 - 237

### **Greenbank DWS Table 8**

Summary of Treated Water Organic Parameter Testing Under Schedule 24 of O. Reg. 170/03.

Parameter	Number	Results	MAC	Unit of	MAC	Potential Sources
	of	Range		Measure	Exceedance	
	Samples					
Alachlor	1	Non-	5	Microgram	N/R	Agricultural herbicide.
		Detect		per Litre		
		(ND)		(ug/L)		
Atrazine + N-dealkylated	1	ND	5	ug/L	N/R	Agricultural herbicide.
metabolites						
Azinphos-methyl	1	ND	20	ug/L	N/R	Insecticide.
Benzene	2	ND	1	ug/L	N/R	Plastics manufacturing, leaking
						fuel tanks.
Benzo(a)pyrene	1	ND	0.01	ug/L	N/R	Formed from the incomplete
						burning of organic matter.
Bromoxynil	1	ND	5	ug/L	N/R	Agricultural herbicide.
Carbaryl	1	ND	90	ug/L	N/R	Agricultural, forestry,
						household insecticide.

# **Greenbank DWS Table 8 continued**

Parameter	Number of	Results	MAC	Unit of	MAC	Potential Sources
	Samples	Range		Measure	Exceedance	
Carbofuran	1	Non-	90	Microgram	N/R	Agricultural insecticide.
		Detect		per Litre		
		(ND)		(ug/L)		
Carbon Tetrachloride	2	ND	2	ug/L	N/R	Chemical and industrial
						activities.
Chlorpyrifos	1	ND	90	ug/L	N/R	Agricultural, household
						insecticide.
Diazinon	1	ND	20	ug/L	N/R	Agricultural, livestock,
						operation, residential
						insecticide.
Dicamba	1	ND	120	ug/L	N/R	Agricultural herbicide
1,2-Dichlorobenzene	2	ND	200	ug/L	N/R	Chemical and industrial
						factories.
1,4-Dichlorobenzene	2	ND	5	ug/L	N/R	Chemical and industrial
						factories.
1,2-Dichloroethane	2	ND	5	ug/L	N/R	Industrial chemical factories.
4.4 Diablamadhulana (visudidana	0	NID	4.4	/1	NI/D	In direction of a construction
1,1-Dichloroethylene (vinylidene chloride)	2	ND	14	ug/L	N/R	Industrial chemical factories.
Dichloromethane	2	ND	50	ug/L	N/R	Pharmaceutical and chemical
						factories.
2,4-Dichlorophenol	1	ND	900	ug/L	N/R	Industrial contamination,
						reaction with chlorine.
2,4-Dichlorophenoxy acetic acid	1	ND	100	ug/L	N/R	Agricultural, residential
(2,4-D)						herbicide.

# **Greenbank DWS Table 8 continued**

Parameter	Number of	Results	MAC	Unit of	MAC	Potential Sources
	Samples	Range		Measure	Exceedance	
Diclofop-methyl	1	Non- Detect (ND)	9	Microgram per Litre (ug/L)	N/R	Agricultural herbicide.
Dimethoate	1	ND	20	ug/L	N/R	Agricultural, livestock, operation, residential insecticide.
Diquat	1	ND	70	ug/L	N/R	Agricultural, aquatic herbicide.
Diuron	1	ND	150	ug/L	N/R	Agricultural, industrial herbicide.
Glyphosate	1	ND	280	ug/L	N/R	Agricultural, forestry, household herbicide.
Malathion	1	ND	190	ug/L	N/R	Pest control insecticide.
2-Methyl-4- chlorophenoxyacetic acid (MCPA)	1	ND	100	ug/L	N/R	Agricultural herbicide.
Metolachlor	1	ND	50	ug/L	N/R	Agricultural herbicide.
Metribuzin	1	ND	80	ug/L	N/R	Agricultural herbicide.
Monochlorobenzene	2	ND	80	ug/L	N/R	Industrial and agricultural chemical factories and dry cleaning facilities.
Paraquat	1	ND	10	ug/L	N/R	Agricultural, aquatic herbicide.
Pentachlorophenol	1	ND	60	ug/L	N/R	Pesticide, wood preservative residue.
Phorate	1	ND	2	ug/L	N/R	Agricultural insecticide.

# **Greenbank DWS Table 8 continued**

Parameter	Number of	Results	MAC	Unit of	MAC	Potential Sources
	Samples	Range		Measure	Exceedance	
Picloram	1	Non-	190	Microgram	N/R	Industrial herbicide.
		Detect		per Litre		
		(ND)		(ug/L)		
Polychlorinated	1	ND	3	ug/L	N/R	Residue from various
Biphenyls(PCB)						industrial uses.
Prometryne	1	ND	1	ug/L	N/R	Agricultural herbicide.
Simazine	1	ND	10	ug/L	N/R	Agricultural herbicide.
Terbufos	1	ND	1	ug/L	N/R	Agricultural insecticide.
Tetrachloroethylene	2	ND	10	ug/L	N/R	Leaching from PVC pipes;
(perchloroethylene)						discharge from factories; dry
						cleaners and auto shops
						(metal degreaser).
2,3,4,6 - Tetrachlorophenol	1	ND	100	ug/L	N/R	Wood preservative.
Triallate	1	ND	230	ug/L	N/R	Agricultural herbicide.
Trichloroethylene	2	ND	5	ug/L	N/R	Metal degreasing sites and
						other factories.
2,4,6-Trichlorophenol	1	ND	5	ug/L	N/R	Pesticide manufacturing.
Trifluralin	1	ND	45	ug/L	N/R	Agricultural herbicide.
Vinyl Chloride	2	ND	1	ug/L	N/R	Leaching from PVC pipes;
						discharge from plastics
						factories.

Inorganic or Organic Parameter(s) that Exceed Half the Standard Prescribed in Schedule 2 of the Ontario Drinking Water Quality Standards.

No inorganic or organic parameters exceeded half the maximum allowable concentration in 2024.