



**NOTES**

1. REPLACED WATERMAIN SHALL BE FLEXIBLE SO THAT IN THE EVENT OF TRENCH SETTLEMENT NO BREAKS WILL OCCUR. THE SOLID SLEEVES WILL TAKE UP THE DEFLECTION DUE TO TRENCH SETTLEMENT.
2. GRADE OF SERVICE OR MAIN PIPE SHALL BE RAISED 150 mm OVER  $\phi$  OF WATERMAIN FOR FLEXIBILITY.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.



**REPLACING BURIED AC OR  
GREY IRON WATERMAIN**

|                    |
|--------------------|
| DWG. DATE: 1978 03 |
| REVISION NO.: 6    |
| REV. DATE: 2013 04 |
| SCALE: N.T.S.      |

**S-201.010**