



NOTES

1. JOINTS SHALL BE MECHANICALLY RESTRAINED.
2. BEDDING AS PER S-200.010.
3. HYDRANT EXTENSIONS SHALL BE INSTALLED AT BOTTOM OF BARREL.
4. ANCHOR TEE, VALVE & HYDRANT SHALL BE COMPLETELY BACKFILLED WITH 19 mm CRUSHER RUN LIMESTONE.
5. IF HYDRANT REQUIRES ACCESS ACROSS DITCH, INSTALLATION SHALL BE AS PER S-210.030.
6. TRACER WIRE COATED, AS PER AMPL.
7. TRACER WIRE SHALL BE INSTALLED AT ALL HYDRANT LOCATIONS.
8. CATHODIC PROTECTION, BONDING CABLE AND TRACER WIRE SHALL BE AS PER S-201.030, S-201.031.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.



**HYDRANT SET WITH
MECHANICALLY RESTRAINED JOINTS**

DWG. DATE: 1978 03
 REVISION NO.: 19
 REV. DATE: 2017 04
 SCALE: N.T.S.

S-210.010