



NOTES

1. BY-PASS LINES MAY BE INSTALLED STAGGERED AS SHOWN OR WITH BY-PASS 2 MAINSTOPS OUTSIDE BY-PASS 1, PROVIDED THERE IS ACCEPTABLE SPACE BETWEEN MAINSTOPS ON THE SAME SIDE OF THE WATERMAIN PIPE.
2. MIN. SEPARATION OF SADDLES TO BE AS PER PIPE MANUFACTURER'S SPECIFICATIONS
3. PVC WATERMAIN SHALL BE TAPPED USING SERVICE SADDLE. SADDLES NOT REQUIRED ON FERROUS WATERMAIN.
4. BY-PASS LINE MUST BE LESS THAN 100mm IN DIAMETER.

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.



WORKS DEPARTMENT

TEMPORARY VALVE BY-PASS ARRANGEMENT

DWG. DATE: 2014 04

REVISION NO.: 1

REV. DATE: 2015 04

SCALE: N.T.S.

S-210.041