



TYPICAL OFFSET VENT FOR AIR VALVE CHAMBER

NOTES

1. PRECAST FLAT TOP SHALL BE USED.
2. SIZES INDICATED ARE MINIMUM. DESIGN ENGINEER SHALL DETERMINE THE APPROPRIATE SIZE OF AIR/VACUUM RELIEF VALVE AND APPURTENANCES.
3. ALL FITTINGS SHALL BE BRASS.
4. AN IDENTIFICATION PLATE PROVIDED BY THE REGION OF DURHAM SHALL BE AFFIXED TO THE VENT PIPE AS SHOWN.

PIPE DIAMETER	MANHOLE DIAMETER	FLANGED BRANCH	AIR RELIEF SIZE	VENT SIZE
400	1200	400	50	100
600	1500	600	50	100
750	1500	600	75	100

ALL DIMENSIONS IN MILLIMETRES EXCEPT WHERE NOTED.



WORKS DEPARTMENT

**AIR VALVE & ACCESS CHAMBER
(FOR WATERMAINS UP TO 750 mm)**

DWG. DATE: 1978 03
 REVISION NO.: 16
 REV. DATE: 2022 02
 SCALE: N.T.S.

S-220.050